



SECTION 8B
HIGH PRESSURE SERVICE

An applicant for water service cannot be assured of a supply of proper pressure where the building site or meter location of the premises will be located in a pressure zone above that which would normally provide water service at that elevation. A High Pressure Service may be granted for premises located at such elevations under all of the following conditions:

1. The District has determined that a standard distribution system to provide the premises with proper pressure is not presently feasible.
2. The applicant shall agree in writing to install and properly maintain a pressure regulator on the applicant's side of the meter, at the applicant's own risk and expense, to ensure a proper water supply and pressure at the premises at all times.
3. The owner(s) of the premises shall agree in writing to accept such service as the District is able to furnish from its existing distribution system. This agreement shall be a covenant against the premises to be served and shall run with the land, and will be recorded by the District at the County Records Office.