

## EXAMPLE WELL FLOW TEST

### WELL FLOW TEST

Property:

TIME	METER READING (G.P.M.)	WATER LEVEL (FT)
1:00 pm	17360 16	101'
1:15 pm	17630 16	117'
1:30 pm	17940 16	125
1:45 pm	18230 16	135
2:00 pm	18530 16	146
2:15 pm	18840 17	149
2:30 pm	19130 17	152
2:45 pm	19420 17	155
3:00 pm	19710 17	157
3:15 pm	20000 17	158
3:30 pm	20290 16	161
3:45 pm	20540 15	162
4:00 pm	20800 16	165
4:15 pm	21030 15	171
4:30 pm	21270 15	172
4:45 pm	21500 16	171
5:00 pm	21730 16	173
		172
		172

Well depth	230
Water static level	80
Pump depth	200
Water pumping level	
Pump size and horsepower	horse and half 15 gallon min pump
Wire	12
Pipe	1 1/2" 80
Pressure system	50/40

TEST PERFORMED BY x [Signature] DATE:

# EXAMPLE WELL FLOW TEST

## FLOW TEST

**OWNER:**

**TEST DATE**

**FLOW TEST CONDUCT BY:**

**DEPTH OF WELL** 72  
**DEPTH TO PUMP** 60 feet  
**CASING** 8 inch steel  
**STATIC WATER LEVEL** 13 feet

	<u>TIME</u>	<u>WATER LEVEL</u>	<u>GPM</u>
<b>TART TIME</b>	11:00	12	20
	11:30	17	20
	12:00	20	20
	12:30	20	20
	1:00	20	20
	1:30	20	20
	2:00	20	20
	2:30	20	20
	3:00	20	20

**LENGTH OF TEST** 4 hours

**RECOVERY** 15 min.

This well produces 20 gallons per minuet